

The H₂O Base, Inc

The H₂O Base, Inc
7068 Easton Road
Pipersville, PA 18947
(215) 766-0340

BACTERIOLOGICAL – CHEMICAL Water Analysis Report

Robert Clinton Auction
956 Bypass Road
Perkasie, PA 18944

Date Sampled: 07/20/2021

Date Tested: 07/20/2021

Date Reported: 07/22/2021

The following is a report of the results of bacteriological and chemical examination of the sample of water collected:

SAMPLE Address	Coliform Results	Ph	Iron	Calcium	Misc.	Sample Picked-Up or Brought-In
956 Bypass Road	Absent	7.3	0.1 PPM	13.5 GPG		Picked-Up
Public Health Standards	Does Meet Drinking Standard	6.5 or Above	Less than 0.3 PPM	No Limit (# GPG)		

Present – Coliform Bacteria present at time of sampling.
Not safe for drinking purposes.

Absent – No Coliform Bacteria present at time of sampling.
Meets drinking water standard.

There is no bacteria present at the time of testing

REMARKS:

THESE TEST RESULTS ARE INTENDED TO BE USED FOR INFORMATIONAL PURPOSES ONLY AND MAY NOT BE USED FOR REGULATORY COMPLIANCE.

BASED ON COLITAG 16 hour BACTERIA TEST